# Installation Manual SIBER® FLEXIBLE DRY TRAP



## FLEXIBLE TRAP FOR THE SIBER DF EVO UNITS


- Allows the drainage of the condensates from the ventilation unit.
- Can be fitted vertically or horizontally.



## **TECHNICAL CHARACTERISTICS**


- Measurements in millimetres (mm)
- · Flexible trap
- Silicon membrane









Direct the arrow marked on the trap in the direction the drain



#### **INSTALLATION**

- Screw in the PVC joint hose and connect the part that goes to the unit to the trap, a 32 mm diameter condensation drain pipe can be connected to the other side.
- The condensate drain pipe can be fitted underneath. The installer can adjust the condensate drain into the desired position.







# Note:

In the case of ceiling installation: install the condensate trap in the drain on the side of the pipes that are connected to the outside. The other drain must be capped with the plug.

In the case of wall installation: install the condensate trap in the bottom drain of the device. The other drain must be capped with the plug.



# Note:

In the case of heat recovery models, both drains must be closed with plugs as the trap is not necessary.





#### Important!

Adjust the trap so that its outlet position is lower than the unit's drain.